

December 23, 2004

JEOVANNY RODRIGUEZ  
355 ALHAMBRA CIRCLE 900  
CORAL GABLES , FL 33134

**RE: Public Hearing Application #Z2004000431  
6425 CORP.**

Dear JEOVANNY RODRIGUEZ :

In order to process the aforementioned public hearing application, the following items must be submitted to this office as soon as possible. Processing of this application will be withheld until the comments and deficiencies listed below have been addressed.

1. On Sheets A-1 & A-2, please review Sec. 33-11(c) Safe Sight Distance Triangle. The height of fences, walls, bus shelters and hedges shall not exceed two and one-half (2.5) feet in height within ten (10) feet of the edge of driveway leading to a public right-of-way. Please see attached.

If plans are requested above, submit six (6) complete sets, along with a reduced 8 ½" x 11" copy to be sent to my attention.

If you have any questions regarding this matter, please do not hesitate to contact me. I can be reached by calling (305) 375-2640.

Sincerely,

A handwritten signature in cursive script that reads "Jose Hernandez". The signature is fluid and extends to the right with a long, sweeping underline.

Jose Hernandez  
Zoning Hearings Section

DEFICIENCY LETTER